ADDENDUM TO THE FACT SHEET
FOR NATIONAL POLLUTANT DISCHARGE
ELIMINATION SYSTEM (NPDES)
PERMIT NO. WA-0044792

I. GENERAL INFORMATION

Facility: City of Oakesdale
P.O. Box 246
Oakesdale, WA 99158

II. APPLICATION REVIEW

An application for permit reissuance was submitted to the Department of Ecology (Department) on January 26 2006, and accepted by the Department on May 1, 2006. The scope and manner of any review of an application for replacement of permit by the Department shall be sufficiently detailed as to insure the following:

- That the permittee is in substantial compliance with all of the terms, conditions, requirements and schedules of compliance of the expired permit;
- That the Department has up-to date information on the permittee's production levels; permittee's waste treatment practices; nature, content, and frequencies of permittee's discharge; either pursuant to the submission of new forms and applications or pursuant to monitoring records and reports resubmitted to the Department by the permittee; and
- That the discharge is consistent with applicable effluent standards and limitations, water quality standards, and other legally applicable requirements listed in WAC 173-220-130.

The application for the City of Oakesdale was reviewed and indicates that no changes in the treatment characteristics of the effluent process or volume of wastewater have occurred.

III. PERMIT REAUTHORIZATION

This fact sheet addendum accompanies the draft permit, which is to be reauthorized to the City of Oakesdale for the discharge of wastewater to the McCoy Creek. The previous fact sheet is also part of this administrative record and explains the basis for the discharge limitations and conditions of the reauthorized permit.

The existing permit requirements, including discharge limitations and monitoring, do not need to be changed to protect the receiving water quality. The previous fact sheet addressed conditions and issues at the facility at the time when the previous permit was issued, and statements made reflected the status in 2001. Since the issuance of the current permit, the Department has not received any information which indicates that environmental impacts from the discharge that were not evaluated at the time of the last permit issuance is persuasive enough to undertake a complete renewal of the permit. The reauthorized permit is virtually identical to the previous permit issued on June 21, 2001.

The discharge limits and conditions in effect at the time of expiration of the previous permit are carried over unchanged to this reauthorized permit. Assessment of compliance and inspections of the facility during the previous permit term indicate that the facility should not be placed on a high priority for permit renewal. The Department assigns a high priority for permit renewals in situations where water quality would materially benefit from a more stringent permit during the next five-year cycle.

The permit reauthorization process, in concert with the routine renewal of high priority permits, allows the Department to reissue permits in a timely manner and minimize the number of active permits that have passed expiration dates. A system of ranking the relative significance of the environmental benefit to be gained by renewing a permit rather than reauthorizing a permit is followed during the Department's annual permit planning process. Each permit that is due for reissuance is assessed and compared with other permits that are also due for reissuance. The public is notified and input is sought after the initial draft ranking has tentatively established which permits are likely to be completely renewed and which are likely to be reauthorized. All relevant comments and suggestions are considered before a final decision is made regarding the type of reissuance for each permit.

The only changes to the previous permit are the submittal date requirements. Submittal requirements from the previous permit that were completed and submitted and do not require additional or continued assessment were removed from this permit. The submittal dates for the other standard compliance and submittal requirements that have been carried over from the past permit into this reauthorized permit have been adjusted to the proposed permit schedule. The Department considered these submittals necessary in the previous permit and no information has come forward to cause a reconsideration of the submittal requirement.

Public notice of the availability of the draft reauthorized permit is required at least 30 days before the permit is issued [Washington Administrative Code (WAC) 173-220-050]. The fact sheet and draft permit are available for review (see Appendix A—Public Involvement for more detail on the Public Notice procedures).

After the public comment period has closed, the Department will summarize the substantive comments and the response to each comment. The summary and response to comments will become part of the file for the permit and parties submitting comments will receive a copy of the Department's response. Comments and the resultant changes to the permit will be summarized in the fact sheet addendum, Appendix D—Response to Comments.

IV. RECOMMENDATION FOR PERMIT ISSUANCE

The Department proposes that this permit be issued for five years.

APPENDIX A – PUBLIC INVOLVEMENT INFORMATION

The Department has determined to reauthorize a discharge permit to the applicant listed on page 1 of this fact sheet addendum. The permit contains conditions and effluent limitations that are described in the fact sheet.

The Department will publish a Public Notice of Draft (PNOD) on , in to inform the public that a draft permit and fact sheet are available for review. Interested persons are invited to submit written comments regarding the draft permit. The draft permit, fact sheet addendum, and fact sheet are available for inspection and copying between the hours of 8:00 a.m. and 5:00 p.m. weekdays, by appointment, at the regional office listed below. Written comments should be mailed to:

Water Quality Permit Coordinator
Department of Ecology
Eastern Regional Office
4601 North Monroe Street
Spokane, WA 99205-1295

Any interested party may comment on the draft permit or request a public hearing on this draft permit within the 30-day comment period to the address above The request for a hearing shall indicate the interest of the party and the reasons why the hearing is warranted. The Department will hold a hearing if it determines there is a significant public interest in the draft permit (WAC 173-220-090). Public notice regarding any hearing will be circulated at least 30 days in advance of the hearing. People expressing an interest in this permit will be mailed an individual notice of hearing (WAC 173-220-100).

Comments should reference specific test followed by proposed modification or concern when possible. Comments may address technical issues, accuracy and completeness of information, the scope of the facility's proposed coverage, adequacy of environmental protection, permit conditions, or any other concern that would result from reauthorization of this permit.

The Department will consider all comments received within 30 days from the date of the PNOD indicated above, in formulating a final determination to issue, revise, or deny the permit. The Department's response to all significant comments is available upon request and will be mailed directly to people expressing an interest in this permit.

Further information may be obtained from the Department by telephone at (509) 329-3567, or by writing to the address listed above.

FACT SHEET FOR NPDES PERMIT WA-004479-2
TOWN OF OAKESDALE STP

SUMMARY

Applicant:	Town of Oakesdale
Facility Name and Address:	Town of Oakesdale POTW P.O. Box 246 Oakesdale, WA 99158
Type of Treatment:	2 Cell Facultative Lagoons, followed by Chlorination and seasonal discharge (November to May) to McCoy Creek.
Location:	Southeast of town, adjacent to McCoy Creek. The site is north of State Highway No. 27, east of the Railroad Tracks. N½ of the NW¼ of Section 26, T.19 N., R. 44 E.W.M. Latitude: 47 ° 07 ' 18 " N. Longitude: 117 ° 13 ' 14 "W

TABLE OF CONTENTS

INTRODUCTION

The Federal Clean Water Act (FCWA, 1972, and later modifications, 1977, 1981, and 1987) established water quality goals for the navigable (surface) waters of the United States. One of the mechanisms for achieving the goals of the Clean Water Act is the National Pollutant Discharge Elimination System of permits (NPDES permits), which is administered by the Environmental Protection Agency (EPA). The EPA has delegated responsibility to administer the NPDES permit program to the State of Washington on the basis of Chapter 90.48 RCW which defines the Department of Ecology's authority and obligations in administering the wastewater discharge permit program.

The regulations adopted by the State include procedures for issuing permits (Chapter 173-220 WAC), technical criteria for discharges from municipal wastewater treatment facilities (Chapter 173-221 WAC), water quality criteria for surface and ground waters (Chapters 173-201A and 200 WAC), and sediment management standards (Chapter 173-204 WAC). These regulations require that a permit be issued before discharge of wastewater to waters of the state is allowed. The regulations also establish the basis for effluent limitations and other requirements which are to be included in the permit. One of the requirements (WAC 173-220-060) for issuing a permit under the NPDES permit program is the preparation of a draft permit and an accompanying fact sheet. Public notice of the availability of the draft permit is required at least thirty days before the permit is issued (WAC 173-220-050). The fact sheet and draft permit are available for review (see Appendix A--Public Involvement of the fact sheet for more detail on the Public Notice procedures).

The fact sheet and draft permit have been reviewed by the Permittee. Errors and omissions identified in this review have been corrected before going to public notice. After the public comment period has closed, the Department will summarize the substantive comments and the response to each comment. The summary and response to comments will become part of the file on the permit and parties submitting comments will receive a copy of the Department's response. The fact sheet will not be revised. Comments and the resultant changes to the permit will be summarized in Appendix D--Response to Comments.

GENERAL INFORMATION	
Applicant	Town of Oakesdale
Facility Name and Address	P.O. Box 246 Oakesdale, WA 99158
Type of Treatment:	Waste Stabilization Lagoons followed by Chlorination
Discharge Location	McCoy Creek Latitude: 47° 07' 18" N Longitude: 117° 13' 14" W.
Water Body ID Number	16-34-01

BACKGROUND INFORMATION

The town of Oakesdale is located about 40 miles south, southeast of Spokane and about 35 miles north of Pullman, in Whitman County. This region of the state is known as the Palouse – an area of generally sloping valleys and rolling hills. The deep fertile soils make the region an important agricultural area for the state.

The Oakesdale area enjoys a moderate climate with summer temperatures averaging about 80° F, with high temperatures occasionally reaching into the 100's and winter temperatures averaging about 30°F and lows around zero. Annual precipitation averages about 20 inches.

Th region is drained by a few permanent streams and numerous intermittent streams. The existing Oakesdale treatment plant discharges into one of these permanent streams, McCoy Creek, a tributary of Spring Creek, which flows to Pine Creek and ultimately to the Palouse River.

The current population of Oakesdale is about 450 and has maintained itself over the past 20 years or so. The Oakesdale Comprehensive Plan, completed in the 80's projected that the population would decline to around 360, so the stability in numbers was not expected.

DESCRIPTION OF THE FACILITY

HISTORY

The original collection system was constructed sometime before 1930 and consisted of about 19,000 lineal feet of clay tile pipe. The collection system gravity discharged the collected wastewater to a community septic tank just west of the lagoon system, and across McCoy Creek. The effluent from the septic tank then discharged into McCoy Creek. The system was upgraded in 1967, with installation of a lift station and the construction of a two cell lagoon system and chlorination prior to discharge to McCoy Creek. The old septic tank was used as an emergency bypass, and was not finally abandoned until the early '80's.

In 1989, the latest upgrade was completed. This work included a new chlorine contact basin, laboratory/maintenance building and a direct flow measurement device. The collection system, which was determined to be infiltrating excessive amounts of extraneous water, was almost completely replaced and the old collection system was converted to a storm sewer. Standby power for the lift station was also installed.

COLLECTION SYSTEM STATUS

The collection system is new as of 1989. The system is designed for a population of 440, dry weather flow of 44,000 gpd, a maximum daily flow of 160,000 gpd. The lift station has a capacity of 400 gpm for each of the duplex pumps, and a capacity of 575 gpm with both pumps running.

TREATMENT PROCESSES

The treatment process consists of two facultative lagoons which can be operated either in series or in parallel. Normal operation is in series. The first cell (primary) is 3.5 surface acres and holds approximately 5.1 million gallons. The second cell (secondary) is 1.5 acres and holds

approximately 2 8 million gallons. Therefore, at design, the hydraulic detention time of the two cells is about 180 days. This allows the facility to seasonally discharge.

The chlorine contact basin has a volume of 7800 gallons, which gives 68 minutes at the maximum daily flow. The length to width ratio for the basin is 56:1. Discharge is to McCoy Creek via an outfall pipe.

DISCHARGE OUTFALL

Secondary treated and disinfected effluent is discharged from the facility into McCoy Creek which discharges to Spring Creek and ultimately to Pine Creek. At this time, there is no information on McCoy Creek, since (as indicated by maps) it is an intermittent stream. We will recommend that in this upcoming permit cycle, the town institute monitoring of the water quality in the creek.

RESIDUAL SOLIDS

The treatment facilities remove solids during the treatment of the wastewater in the lagoons and in the chlorine contact basin, in addition to incidental solids (rags, scum, and other debris) removed as part of the routine maintenance of the equipment. Grit, rags, scum and screenings are drained and disposed of as solid waste at the local landfill. Solids removed from the lagoons will be land applied under a permit from the Whitman County Health District.

PERMIT STATUS

The previous permit for this facility was issued on March 11, 1996. The previous permit placed effluent limitations on 5-day Biochemical Oxygen Demand (BOD_5), Total Suspended Solids (TSS), pH, and Fecal Coliform bacteria.

An application for permit renewal was submitted to the Department on September 29, 1999 and accepted by the Department on October 28, 1999.

SUMMARY OF COMPLIANCE WITH THE PREVIOUS PERMIT

The facility received its last inspection on July 31, 1997.

During the history of the previous permit, the Permittee has essentially remained in compliance, based on discharge Monitoring Reports (DMRs) submitted to the Department and inspections conducted by the Department. The percent removal for BOD and TSS is above that in the permit. However, it is within the limits prescribed by the "Alternative Domestic Wastewater Facility Discharge Standards and Effluent Limitations" for waste stabilization lagoons. The effluent limits in the permit will be modified, but only for the percent removals. The facility has demonstrated its ability to provide treatment to meet the 30 mg/L requirements.

WASTEWATER CHARACTERIZATION

The concentration of pollutants in the discharge was reported in the NPDES application and in discharge monitoring reports. The effluent, from the period September, 1998 to September, 2000, is characterized as follows:

Table 1: Wastewater Characterization

Parameter	Concentration
Maximum Influent Flow (gpd)	156,000 gpd
Average Influent Flow (gpd)	66,000 gpd
BOD	20.8 mg/L
BOD	33.91 lb/day
BOD (% removal)	81%
TSS	18.7 mg/L
TSS	30.64 lb/day
TSS (% removal)	65%
pH	8.19 – 8.59 s.u.
Chlorine Residual	0.33 mg/L
Average fecal coliform	55.5/100 mL
Maximum fecal coliform	130/100 mL

SEPA COMPLIANCE
There are no outstanding SEPA issues with this facility.

PROPOSED PERMIT LIMITATIONS

Federal and State regulations require that effluent limitations set forth in a NPDES permit must be either technology- or water quality-based. Technology-based limitations for municipal discharges are set by regulation (40 CFR 133, and Chapters 173-220 and 173-221 WAC). Water quality-based limitations are based upon compliance with the Surface Water Quality Standards (Chapter 173-201A WAC), Ground Water Standards (Chapter 173-200 WAC), Sediment Quality Standards (Chapter 173-204 WAC) or the National Toxics Rule (Federal Register, Volume 57, No. 246, Tuesday, December 22, 1992.) The most stringent of these types of limits must be chosen for each of the parameters of concern. Each of these types of limits is described in more detail below.

The limits in this permit are based in part on information received in the application. The effluent constituents in the application were evaluated on a technology- and water quality-basis. The limits necessary to meet the rules and regulations of the State of Washington were determined and included in this permit. Ecology does not develop effluent limits for all pollutants that may be reported on the application as present in the effluent. Some pollutants are not treatable at the concentrations reported, are not controllable at the source, are not listed in regulation, and do not have a reasonable potential to cause a water quality violation. Effluent limits are not always developed for pollutants that may be in the discharge but not reported as present in the application. In those circumstances the permit does not authorize discharge of the non-reported pollutants. Effluent discharge conditions may change from the conditions reported in the permit application. If significant changes occur in any constituent, as described in 40 CFR 122.42(a), the Permittee is required to notify the Department of Ecology. The Permittee may be in violation of the permit until the permit is modified to reflect additional discharge of pollutants.

DESIGN CRITERIA

In accordance with WAC 173-220-150 (1)(g), flows or waste loadings shall not exceed approved design criteria.

The design criteria for this treatment facility are taken from 1991 "One Year Certification" prepared by Anderson Perry and Associates and are as follows:

Table 2: Design Standards for the Town of Oakesdale WWTP.

Parameter	Design Quantity
Monthly average flow (max. month)	160,000 gpd
Monthly average dry weather flow	44,000 gpd
Monthly average wet weather flow	160,000 gpd
Instantaneous peak flow	450,000 gpd
BOD_5 influent loading	90 lb./ day
TSS influent loading	90 lb./ day
Design population equivalent	440

TECHNOLOGY-BASED EFFLUENT LIMITATIONS

Municipal wastewater treatment plants are a category of discharger for which technology-based effluent limits have been promulgated by federal and state regulations. These effluent limitations are given in the Code of Federal Regulations (CFR) 40 CFR Part 133 (federal) and in Chapter 173-221 WAC (state). These regulations are performance standards that constitute all known available and reasonable methods of prevention, control, and treatment for municipal wastewater.

The following technology-based limits for pH, fecal coliform, BOD_5, and TSS are taken from Chapter 173-221 WAC are:

Table 3: Technology-based Limits.

Parameter	Limit
pH:	shall be within the range of 6 to 9 standard units.
Fecal Coliform Bacteria	Monthly Geometric Mean = 200 organisms/100 mL Weekly Geometric Mean = 400 organisms/100 mL
BOD_5 (concentration)	Average Monthly Limit is the most stringent of the following: - 30 mg/L - may not exceed thirty five percent (35%) of the average influent concentration (Alternative Limitations). Average Weekly Limit = 45 mg/L

Parameter	Limit
TSS (concentration)	Average Monthly Limit is the most stringent of the following: - 30 mg/L - may not exceed thirty five percent (35%) of the average influent concentration (Alternative Limitations). Average Weekly Limit = 45 mg/L
	Average Monthly Limit = 0.5 mg/L Average Weekly Limit = 0.75 mg/L

The technology-based monthly average limitation for chlorine is derived from standard operating practices. The Water Pollution Control Federation's Chlorination of Wastewater (1976) states that a properly designed and maintained wastewater treatment plant can achieve adequate disinfection if a 0.5 mg/liter chlorine residual is maintained after fifteen minutes of contact time. See also Metcalf and Eddy, Wastewater Engineering, Treatment, Disposal and Reuse, Third Edition, 1991. A treatment plant that provides adequate chlorination contact time can meet the 0.5 mg/liter chlorine limit on a monthly average basis. According to WAC 173-221-030(11)(b), the corresponding weekly average is 0.75 mg/liter.

The existing permit has a chlorine limit of 0.5 mg/L and the facility is able to comply with it. The proposed permit includes the same limit.

The following technology-based mass limits are based on WAC 173-220-130(3)(b) and 173-221-030(11)(b).

Monthly effluent mass loadings (lbs/day) were calculated as the maximum monthly design flow (0.16 MGD) x Concentration limit (30 mg/L) x 8.34 (conversion factor) = mass limit 40 lb./day.

SURFACE WATER QUALITY-BASED EFFLUENT LIMITATIONS

In order to protect existing water quality and preserve the designated beneficial uses of Washington's surface waters, WAC 173-201A-060 states that waste discharge permits shall be conditioned such that the discharge will meet established Surface Water Quality Standards. The Washington State Surface Water Quality Standards (Chapter 173-201A WAC) is a state regulation designed to protect the beneficial uses of the surface waters of the state. Water quality-based effluent limitations may be based on an individual waste load allocation (WLA) or on a WLA developed during a basin-wide total maximum daily loading study (TMDL).

NUMERICAL CRITERIA FOR THE PROTECTION OF AQUATIC LIFE

"Numerical" water quality criteria are numerical values set forth in the State of Washington's Water Quality Standards for Surface Waters (Chapter 173-201A WAC). They specify the levels of pollutants allowed in a receiving water while remaining protective of aquatic life. Numerical criteria set forth in the Water Quality Standards are used along with chemical and physical data for the wastewater and receiving water to derive the effluent limits in the discharge permit. When surface water quality-based limits are more stringent or potentially more stringent than technology-based limitations, they must be used in a permit.

NUMERICAL CRITERIA FOR THE PROTECTION OF HUMAN HEALTH

The state was issued 91 numeric water quality criteria for the protection of human health by the U.S. EPA (EPA 1992). These criteria are designed to protect humans from cancer and other disease and are primarily applicable to fish and shellfish consumption and drinking water from surface waters.

NARRATIVE CRITERIA

In addition to numerical criteria, "narrative" water quality criteria (WAC 173-201A-030) limit toxic, radioactive, or deleterious material concentrations below those which have the potential to adversely affect characteristic water uses, cause acute or chronic toxicity to biota, impair aesthetic values, or adversely affect human health. Narrative criteria protect the specific beneficial uses of all fresh (WAC 173-201A-130) and marine (WAC 173-201A-140) waters in the State of Washington.

ANTIDEGRADATION

The State of Washington's Antidegradation Policy requires that discharges into a receiving water shall not further degrade the existing water quality of the water body. In cases where the natural conditions of a receiving water are of lower quality than the criteria assigned, the natural conditions shall constitute the water quality criteria. Similarly, when the natural conditions of a receiving water are of higher quality than the criteria assigned, the natural conditions shall constitute the water quality criteria. More information on the State Antidegradation Policy can be obtained by referring to WAC 173-201A-070.

CRITICAL CONDITIONS

Surface water quality-based limits are derived for the waterbody's critical condition, which represents the receiving water and waste discharge condition with the highest potential for adverse impact on the aquatic biota, human health, and existing or characteristic water body uses.

MIXING ZONES

The Water Quality Standards allow the Department of Ecology to authorize mixing zones around a point of discharge in establishing surface water quality-based effluent limits. Both "acute" and "chronic" mixing zones may be authorized for pollutants that can have a toxic effect on the aquatic environment near the point of discharge. The concentration of pollutants at the boundary of these mixing zones may not exceed the numerical criteria for that type of zone. Mixing zones can only be authorized for discharges that are receiving all known, available, and reasonable methods of prevention, control and treatment (AKART) and in accordance with other mixing zone requirements of WAC 173-201A-100.

The National Toxics Rule (EPA, 1992) allows the chronic mixing zone to be used to meet human health criteria.

DESCRIPTION OF THE RECEIVING WATER

The facility discharges to McCoy Creek which discharges to Spring Creek and ultimately to Pine Creek which is designated as a Class A receiving water. Significant nearby non-point sources of pollutants include agricultural runoff. Characteristic uses include the following:

water supply (domestic, industrial, agricultural); stock watering; fish migration; fish rearing, spawning and harvesting; wildlife habitat; primary contact recreation; sport fishing; boating and aesthetic enjoyment; commerce and navigation.

Water quality of this class shall meet or exceed the requirements for all or substantially all uses.

SURFACE WATER QUALITY CRITERIA

Applicable criteria are defined in Chapter 173-201A WAC for aquatic biota. In addition, U.S. EPA has promulgated human health criteria for toxic pollutants (EPA 1992). Criteria for this discharge are summarized below:

Fecal Coliforms	100 organisms/100 mL maximum geometric mean
Dissolved Oxygen	8 mg/L minimum
Temperature	18 degrees Celsius maximum or incremental increases above background
pH	6.5 to 8.5 standard units
Turbidity	less than 5 NTUs above background
Toxics	No toxics in toxic amounts (see Appendix C for numeric criteria for toxics of concern for this discharge)

COMPARISON OF EFFLUENT LIMITS WITH THE EXISTING PERMIT ISSUED March 11, 1996

Existing Limits	Proposed Limits
The average monthly effluent concentration for BOD and TSS shall not exceed 30 mg/L or 15% of the respective monthly average influent influent concentration , whichever is more stringent	The average monthly effluent concentration for BOD and TSS shall not exceed 30 mg/L or 35% of the respective monthly average influent influent concentration , whichever is more stringent (Alternative Limitations)
All other effluent limitations will remain the same.	

MONITORING REQUIREMENTS

Monitoring, recording, and reporting are required (WAC 173-220-210 and 40 CFR 122.41) to verify that the treatment process is functioning correctly and the effluent limitations are being achieved.

Monitoring of sludge quantity and quality is necessary to determine the appropriate uses of the sludge. Sludge monitoring is required by the current state and local solid waste management program and also by EPA under 40 CFR 503.

The monitoring schedule is detailed in the proposed permit under Condition S.2. Specified monitoring frequencies take into account the quantity and variability of discharge, the treatment method, past compliance, significance of pollutants, and cost of monitoring. The required monitoring frequency is consistent with agency guidance given in the current version of Ecology's *Permit Writer's Manual* (July 1994) for stabilization lagoons.

LAB ACCREDITATION

With the exception of certain parameters the permit requires all monitoring data to be prepared by a laboratory registered or accredited under the provisions of Chapter 173-50 WAC, *Accreditation of Environmental Laboratories*.

OTHER PERMIT CONDITIONS

REPORTING AND RECORDKEEPING

The conditions of S3. are based on the authority to specify any appropriate reporting and recordkeeping requirements to prevent and control waste discharges (WAC 173-220-210).

PREVENTION OF FACILITY OVERLOADING

Overloading of the treatment plant is a violation of the terms and conditions of the permit. To prevent this from occurring, RCW 90.48.110 and WAC 173-220-150 require the Permittee to take the actions detailed in proposed permit requirement S.4. to plan expansions or modifications before existing capacity is reached and to report and correct conditions that could result in new or increased discharges of pollutants. Condition S.4. restricts the amount of flow.

OPERATION AND MAINTENANCE (O&M)

The proposed permit contains condition S.5. as authorized under RCW 90.48.110, WAC 173-220-150, Chapter 173-230 WAC, and WAC 173-240-080. It is included to ensure proper operation and regular maintenance of equipment, and to ensure that adequate safeguards are taken so that constructed facilities are used to their optimum potential in terms of pollutant capture and treatment.

RESIDUAL SOLIDS HANDLING

To prevent water quality problems the Permittee is required in permit condition S7. to store and handle all residual solids (grit, screenings, scum, sludge, and other solid waste) in accordance with the requirements of RCW 90.48.080 and State Water Quality Standards.

The final use and disposal of sewage sludge from this facility is regulated by U.S. EPA under 40 CFR 503. The disposal of other solid waste is under the jurisdiction of the Whitman County Health Department.

Requirements for monitoring sewage sludge and recordkeeping are included in this permit. This information will by used by Ecology to develop or update local limits and is also required under 40 CFR 503.

PRETREATMENT

The Department may modify this permit to incorporate additional requirements relating to the establishment and enforcement of local limits for pollutants of concern. Any permit modification is subject to formal due process procedures pursuant to state and federal law and regulation.

Federal and State Pretreatment Program Requirements

Under the terms of the addendum to the "Memorandum of Understanding between Washington Department of Ecology and the United States Environmental Protection Agency, Region 10" (1986), the Department of Ecology (Department) has been delegated authority to administer the Pretreatment Program (i.e. act as the Approval Authority for oversight of delegated Publicly Owned Treatment Works (POTWs)). Under this delegation of authority, the Department has exercised the option of issuing wastewater discharge permits for significant industrial users discharging to POTWs which have not been delegated authority to issue wastewater discharge permits.

There are a number of functions required by the Pretreatment Program which the Department is delegating to such POTWs because they are in a better position to implement the requirements (e.g. tracking the number and general nature of industrial dischargers to the sewerage system). The requirements for a Pretreatment Program are contained in Title 40, part 403 of the Code of Federal Regulations. Under the requirements of the Pretreatment Program (40 CFR 403.8(f)(1)(iii)), the Department is required to approve, condition, or deny new discharges or a significant increase in the discharge for existing significant industrial users (SIUs) (40 CFR 403.8 (f)(1)(i)).

The Department is responsible for issuing State Waste Discharge Permits to SIUs and other industrial users of the Permittee's sewer system. Industrial dischargers must obtain these permits from the Department prior to the Permittee accepting the discharge (WAC 173-216-110(5)) (Industries discharging wastewater that is similar in character to domestic wastewater are not required to obtain a permit. Such dischargers should contact the Department to determine if a permit is required). Industrial dischargers need to apply for a State Waste Discharge Permit sixty days prior to commencing discharge. The conditions contained in the permits will include any applicable conditions for categorical discharges, loading limitations included in contracts

with the POTW, and other conditions necessary to assure compliance with State water quality standards and biosolids standards.

The Department requires this POTW to fulfill some of the functions required for the Pretreatment Program in the NPDES permit (e.g. tracking the number and general nature of industrial dischargers to the sewage system). The POTW's NPDES permit will require that all SIUs currently discharging to the POTW be identified and notified of the requirement to apply for a wastewater discharge permit from the Department. None of the obligations imposed on the POTW relieve an industrial or commercial discharger of its primary responsibility for obtaining a wastewater discharge permit (if required), including submittal of engineering reports prior to construction or modification of facilities (40 CFR 403.12(j) and WAC 173-216-070 and WAC 173-240-110, et seq.).

Wastewater Permit Required

RCW 90.48 and WAC 173-216-040 require SIUs to obtain a permit prior to discharge of industrial waste to the Permittee's sewerage system. This provision prohibits the POTW from accepting industrial wastewater from any such dischargers without authorization from the Department.

Requirements for Routine Identification and Reporting of Industrial Users

The NPDES permit requires non-delegated POTWs to " take continuous, routine measures to identify all existing, new, and proposed SIUs and potential significant industrial users (PSIUs) discharging to the Permittee's sewerage system". Examples of such routine measures include regular review of business tax licenses for existing businesses and review of water billing records and existing connection authorization records. System maintenance personnel can also be diligent during performance of their jobs in identifying and reporting as-yet unidentified industrial dischargers. Local newspapers, telephone directories, and word-of-mouth can also be important sources of information regarding new or existing discharges. The POTW is required to notify an industrial discharger, in writing, of their responsibilities regarding application for a State waste discharge permit and to send a copy of the written notification to the Department. The Department will then take steps to solicit a State waste discharge permit application.

Annual Submittal of List of Industrial Users

This provision requires the POTW to submit annually a list of existing and proposed SIUs and PSIUs. This requirement is intended to update the Department on an annual basis of the status of industrial users in the POTW's service area, without requiring the POTW to go through the process of performing a formal Industrial User Survey. This provision is normally applied to POTWs not serving industrial or commercial users. Although this permit does not require performance of an Industrial User Survey, the Permittee is nevertheless required under the previous section, to take adequate continuous routine measures to identify existing and new industrial discharges.

Duty to Enforce Discharge Prohibitions

This provision prohibits the POTW from authorizing or permitting an industrial discharger to discharge certain types of waste into the sanitary sewer. The first portion of the provision prohibits acceptance of pollutants which cause pass through or interference. The definitions of pass through and interference are in Appendix B of the fact sheet.

The second portion of this provision prohibits the POTW from accepting certain specific types of wastes, namely those which are explosive, flammable, excessively acidic, basic, otherwise corrosive, or obstructive to the system. In addition wastes with excessive BOD, petroleum based oils, or which result in toxic gases are prohibited to be discharged. The regulatory basis for these prohibitions is 40 CFR Part 403, with the exception of the pH provisions which are based on WAC 173-216-060.

The third portion of this provision prohibits certain types of discharges unless the POTW receives prior authorization from the Department. The discharges include cooling water in significant volumes, stormwater and other direct inflow sources, and wastewaters significantly affecting system hydraulic loading, which do not require treatment.

Support by the Department for Developing Partial Pretreatment Program by POTW

The Department has committed to providing technical and legal assistance to the Permittee in fulfilling these joint obligations, in particular assistance with developing an adequate sewer use ordinance, notification procedures, enforcement guidelines, and developing local limits and inspection procedures.

OUTFALL EVALUATION

Proposed permit condition S.9. requires the Permittee to conduct an outfall inspection and submit a report detailing the findings of that inspection. The purpose of the inspection is to determine the condition of the discharge pipe and diffusers and to determine if sediment is accumulating in the vicinity of the outfall.

GENERAL CONDITIONS

General Conditions are based directly on state and federal law and regulations and have been standardized for all individual municipal NPDES permits issued by the Department.

PERMIT ISSUANCE PROCEDURES

PERMIT MODIFICATIONS

The Department may modify this permit to impose numerical limitations, if necessary to meet Water Quality Standards, Sediment Quality Standards, or Ground Water Standards, based on new information obtained from sources such as inspections, effluent monitoring, outfall studies, and effluent mixing studies.

The Department may also modify this permit as a result of new or amended state or federal regulations.

RECOMMENDATION FOR PERMIT ISSUANCE

This proposed permit meets all statutory requirements for authorizing a wastewater discharge, including those limitations and conditions believed necessary to protect human health, aquatic life, and the beneficial uses of waters of the State of Washington. The Department proposes that this permit be issued for four years.

REFERENCES FOR TEXT AND APPENDICES

Anderson, Perry and Associates

1991. Town of Oakesdale, One Year Certification, Interim Report.

Environmental Protection Agency (EPA)

1992. National Toxics Rule. Federal Register, V. 57, No. 246, Tuesday, December 22, 1992.

1991. Technical Support Document for Water Quality-based Toxics Control. EPA/505/2-90-001.

1988. Technical Guidance on Supplementary Stream Design Conditions for Steady State Modeling. USEPA Office of Water, Washington, D.C.

1985. Water Quality Assessment: A Screening Procedure for Toxic and Conventional Pollutants in Surface and Ground Water. EPA/600/6-85/002a.

1983. Water Quality Standards Handbook. USEPA Office of Water, Washington, D.C.

Metcalf and Eddy.

1991. Wastewater Engineering, Treatment, Disposal, and Reuse. Third Edition.

Tsivoglou, E.C., and J.R. Wallace.

1972. Characterization of Stream Reaeration Capacity. EPA-R3-72-012. (Cited in EPA 1985 op.cit.)

Washington State Department of Ecology.

1994. Permit Writer's Manual. Publication Number 92-109

Water Pollution Control Federation.

1976. Chlorination of Wastewater.

Wright, R.M., and A.J. McDonnell.

1979. In-stream Deoxygenation Rate Prediction. Journal Environmental Engineering Division, ASCE. 105(EE2). (Cited in EPA 1985 op cit.)

APPENDIX A--PUBLIC INVOLVEMENT INFORMATION

The Department has tentatively determined to reissue a permit to the applicant listed on page 1 of this fact sheet. The permit contains conditions and effluent limitations which are described in the rest of this fact sheet.

Public notice of application was published on September 9 and September 16, 1999 in the Whitman County Gazette to inform the public that an application had been submitted and to invite comment on the reissuance of this permit.

The Department will publish a Public Notice of Draft (PNOD) on May 17, 2001, in the Whitman County Gazette to inform the public that a draft permit and fact sheet are available for review. Interested persons are invited to submit written comments regarding the draft permit. The draft permit, fact sheet, and related documents are available for inspection and copying between the hours of 8:00 a.m. and 5:00 p.m. weekdays, by appointment, at the regional office listed below. Written comments should be mailed to:

Water Quality Permit Coordinator
Department of Ecology
Eastern Regional Office
4601 North Monroe Street, Suite 202
Spokane, WA 99205-1295.

Any interested party may comment on the draft permit or request a public hearing on this draft permit within the thirty (30) day comment period to the address above. The request for a hearing shall indicate the interest of the party and the reasons why the hearing is warranted. The Department will hold a hearing if it determines there is a significant public interest in the draft permit (WAC 173-220-090). Public notice regarding any hearing will be circulated at least thirty (30) days in advance of the hearing. People expressing an interest in this permit will be mailed an individual notice of hearing (WAC 173-220-100).

Comments should reference specific text followed by proposed modification or concern when possible. Comments may address technical issues, accuracy and completeness of information, the scope of the facility's proposed coverage, adequacy of environmental protection, permit conditions, or any other concern that would result from issuance of this permit.

The Department will consider all comments received within thirty (30) days from the date of public notice of draft indicated above, in formulating a final determination to issue, revise, or deny the permit. The Department's response to all significant comments is available upon request and will be mailed directly to people expressing an interest in this permit.

Further information may be obtained from the Department by telephone, (509) 456-2926, or by writing to the address listed above.

This permit and fact sheet were written by Andrew K.S. Tom, P.E.

APPENDIX B--GLOSSARY

Acute Toxicity--The lethal effect of a pollutant on an organism that occurs within a short period of time, usually 48 to 96 hours.

AKART-- An acronym for "all known, available, and reasonable methods of prevention, control, and treatment".

Ambient Water Quality--The existing environmental condition of the water in a receiving water body.

Ammonia--Ammonia is produced by the breakdown of nitrogenous materials in wastewater. Ammonia is toxic to aquatic organisms, exerts an oxygen demand, and contributes to eutrophication. It also increases the amount of chlorine needed to disinfect wastewater.

Average Monthly Discharge Limitation --The highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month (except in the case of fecal coliform). The daily discharge is calculated as the average measurement of the pollutant over the day.

Average Weekly Discharge Limitation -- The highest allowable average of daily discharges over a calendar week, calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week. The daily discharge is calculated as the average measurement of the pollutant over the day.

Best Management Practices (BMPs)--Schedules of activities, prohibitions of practices, maintenance procedures, and other physical, structural and/or managerial practices to prevent or reduce the pollution of waters of the State. BMPs include treatment systems, operating procedures, and practices to control: plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage. BMPs may be further categorized as operational, source control, erosion and sediment control, and treatment BMPs.

BOD_5--Determining the Biochemical Oxygen Demand of an effluent is an indirect way of measuring the quantity of organic material present in an effluent that is utilized by bacteria. The BOD_5 is used in modeling to measure the reduction of dissolved oxygen in a receiving water after effluent is discharged. Stress caused by reduced dissolved oxygen levels makes organisms less competitive and less able to sustain their species in the aquatic environment. Although BOD is not a specific compound, it is defined as a conventional pollutant under the federal Clean Water Act.

Bypass--The intentional diversion of waste streams from any portion of a treatment facility.

Chlorine--Chlorine is used to disinfect wastewaters of pathogens harmful to human health. It is also extremely toxic to aquatic life.

Chronic Toxicity--The effect of a pollutant on an organism over a relatively long time, often 1/10 of an organism's lifespan or more. Chronic toxicity can measure survival, reproduction or growth rates, or other parameters to measure the toxic effects of a compound or combination of compounds.

Clean Water Act (CWA)--The Federal Water Pollution Control Act enacted by Public Law 92-500, as amended by Public Laws 95-217, 95-576, 96-483, 97-117; USC 1251 et seq.

Combined Sewer Overflow (CSO)--The event during which excess combined sewage flow caused by inflow is discharged from a combined sewer, rather than conveyed to the sewage treatment plant because either the capacity of the treatment plant or the combined sewer is exceeded.

Compliance Inspection - Without Sampling--A site visit for the purpose of determining the compliance of a facility with the terms and conditions of its permit or with applicable statutes and regulations.

Compliance Inspection - With Sampling--A site visit to accomplish the purpose of a Compliance Inspection - Without Sampling and as a minimum, sampling and analysis for all parameters with limits in the permit to ascertain compliance with those limits; and, for municipal facilities, sampling of influent to ascertain compliance with the percent removal requirement. Additional sampling may be conducted.

Composite Sample--A mixture of grab samples collected at the same sampling point at different times, formed either by continuous sampling or by mixing a minimum of four discrete samples. May be "time-composite"(collected at constant time intervals) or "flow-proportional" (collected either as a constant sample volume at time intervals proportional to stream flow, or collected by increasing the volume of each aliquot as the flow increased while maintaining a constant time interval between the aliquots.

Construction Activity--Clearing, grading, excavation and any other activity which disturbs the surface of the land. Such activities may include road building, construction of residential houses, office buildings, or industrial buildings, and demolition activity.

Continuous Monitoring –Uninterrupted, unless otherwise noted in the permit.

Critical Condition--The time during which the combination of receiving water and waste discharge conditions have the highest potential for causing toxicity in the receiving water environment. This situation usually occurs when the flow within a water body is low, thus, its ability to dilute effluent is reduced.

Dilution Factor--A measure of the amount of mixing of effluent and receiving water that occurs at the boundary of the mixing zone. Expressed as the inverse of the effluent fraction e.g., a dilution factor of 10 means the effluent comprises 10% by volume and the receiving water 90%.

Engineering Report--A document which thoroughly examines the engineering and administrative aspects of a particular domestic or industrial wastewater facility. The report shall contain the appropriate information required in WAC 173-240-060 or 173-240-130.

Fecal Coliform Bacteria--Fecal coliform bacteria are used as indicators of pathogenic bacteria in the effluent that are harmful to humans. Pathogenic bacteria in wastewater discharges are controlled by disinfecting the wastewater. The presence of high numbers of fecal coliform bacteria in a water body can indicate the recent release of untreated wastewater and/or the presence of animal feces.

Grab Sample--A single sample or measurement taken at a specific time or over as short period of time as is feasible.

Industrial User-- A discharger of wastewater to the sanitary sewer which is not sanitary wastewater or is not equivalent to sanitary wastewater in character.

Industrial Wastewater--Water or liquid-carried waste from industrial or commercial processes, as distinct from domestic wastewater. These wastes may result from any process or activity of industry, manufacture, trade or business, from the development of any natural resource, or from animal operations such as feed lots, poultry houses, or dairies. The term includes contaminated storm water and, also, leachate from solid waste facilities.

Infiltration and Inflow (I/I)--"Infiltration" means the addition of ground water into a sewer through joints, the sewer pipe material, cracks, and other defects. "Inflow" means the addition of precipitation-caused drainage from roof drains, yard drains, basement drains, street catch basins, etc., into a sewer.

Interference -- A discharge which, alone or in conjunction with a discharge or discharges from other sources, both:

Inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal and;

Therefore is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation) or of the prevention of sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent State or local regulations): Section 405 of the Clean Water Act, the Solid Waste Disposal Act (SWDA) (including title II, more commonly referred to as the Resource Conservation and Recovery Act (RCRA), and including State regulations contained in any State sludge management plan prepared pursuant to subtitle D of the SWDA), sludge regulations appearing in 40 CFR Part 507, the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection, Research and Sanctuaries Act.

Major Facility--A facility discharging to surface water with an EPA rating score of > 80 points based on such factors as flow volume, toxic pollutant potential, and public health impact.

Maximum Daily Discharge Limitation--The highest allowable daily discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. The daily discharge is calculated as the average measurement of the pollutant over the day.

Method Detection Level (MDL)--The minimum concentration of a substance that can be measured and reported with 99% confidence that the analyte concentration is above zero and is determined from analysis of a sample in a given matrix containing the analyte.

Minor Facility--A facility discharging to surface water with an EPA rating score of < 80 points based on such factors as flow volume, toxic pollutant potential, and public health impact.

Mixing Zone--A volume that surrounds an effluent discharge within which water quality criteria may be exceeded. The area of the authorized mixing zone is specified in a facility's permit and follows procedures outlined in State regulations (Chapter 173-201A WAC).

National Pollutant Discharge Elimination System (NPDES)--The NPDES (Section 402 of the Clean Water Act) is the Federal wastewater permitting system for discharges to navigable waters of the United States. Many states, including the State of Washington, have been delegated the authority to issue these permits. NPDES permits issued by Washington State permit writers are joint NPDES/State permits issued under both State and Federal laws.

Pass through -- A discharge which exits the POTW into waters of the-State in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation), or which is a cause of a violation of State water quality standards.

pH--The pH of a liquid measures its acidity or alkalinity. A pH of 7 is defined as neutral, and large variations above or below this value are considered harmful to most aquatic life.

Potential Significant Industrial User--A potential significant industrial user is defined as an Industrial User which does not meet the criteria for a Significant Industrial User, but which discharges wastewater meeting one or more of the following criteria:

a. Exceeds 0.5 % of treatment plant design capacity criteria and discharges <25,000 gallons per day or;

b. Is a member of a group of similar industrial users which, taken together, have the potential to cause pass through or interference at the POTW (e.g. facilities which develop photographic film or paper, and car washes).

The Department may determine that a discharger initially classified as a potential significant industrial user should be managed as a significant industrial user.

Quantitation Level (QL)-- A calculated value five times the MDL (method detection level).

Significant Industrial User (SIU)--

1) All industrial users subject to Categorical Pretreatment Standards under 40 CFR 403.6 and 40 CFR Chapter I, Subchapter N and;

2) Any other industrial user that: discharges an average of 25,000 gallons per day or more of process wastewater to the POTW (excluding sanitary, noncontact cooling, and boiler blow-down wastewater); contributes a process wastestream that makes up 5 percent or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant; or is designated as such by the Control Authority* on the basis that the industrial user has a reasonable potential for adversely affecting the POTW's operation or for violating any pretreatment standard or requirement (in accordance with 40 CFR 403.8(f)(6)).

Upon finding that the industrial user meeting the criteria in paragraph 2, above, has no reasonable potential for adversely affecting the POTW's operation or for violating any pretreatment standard or requirement, the Control Authority* may at any time, on its own initiative or in response to a petition received from an industrial user or POTW, and in accordance with 40 CFR 403.8(f)(6), determine that such industrial user is not a significant industrial user.

*The term "Control Authority" refers to the Washington State Department of Ecology in the case of non-delegated POTWs or to the POTW in the case of delegated POTWs.

State Waters--Lakes, rivers, ponds, streams, inland waters, underground waters, salt waters, wetlands, and all other surface waters and watercourses within the jurisdiction of the state of Washington.

Stormwater--That portion of precipitation that does not naturally percolate into the ground or evaporate, but flows via overland flow, interflow, pipes, and other features of a storm water drainage system into a defined surface water body, or a constructed infiltration facility.

Technology-based Effluent Limit--A permit limit that is based on the ability of a treatment method to reduce the pollutant.

Total Suspended Solids (TSS)--Total suspended solids are the particulate materials in an effluent. Large quantities of TSS discharged to a receiving water may result in solids accumulation. Apart from any toxic effects attributable to substances leached out by water, suspended solids may kill fish, shellfish, and other aquatic organisms by causing abrasive injuries and by clogging the gills and respiratory passages of various aquatic fauna. Indirectly, suspended solids can screen out light and can promote and maintain the development of noxious conditions through oxygen depletion.

Upset--An exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, lack of preventative maintenance, or careless or improper operation.

Water Quality-based Effluent Limit--A limit on the concentration or mass of an effluent parameter that is intended to prevent the concentration of that parameter from exceeding its water quality criterion after it is discharged into a receiving water.

APPENDIX C—SITE MAP

Several of the Excel® spreadsheet tools used to evaluate a discharger's ability to meet Washington State water quality standards can be found on the Department's homepage at http.www:wa.gov.ecology.

APPENDIX D--RESPONSE TO COMMENTS